

# **Notice To Bidders**

**The Henry County Board of Supervisors are accepting bids for the Henry County Court House Boiler Replacement Project. Below are the specs done by an Engineer. If you have any questions feel free to contact Derek Wellington in the Henry County Auditor's Office. Sealed bids must be submitted by 4:30 pm January 6, 2012 and will be opened by the Board of Supervisors on January 10, 2012 at 10:00 am. Bids can be left at the Henry County Auditor's Office or mailed to 100 E Washington St., Mt Pleasant, IA 52641.**

**Specs are as followed:**

**Remove existing boilers, condensate tanks and pumps. Clean system piping and radiators. Remove all steam traps. Install a Weil-McLain Ultra 750 and Ultra 550 or equivalent High Efficiency Boilers. Install all new piping from boiler room to the courthouse. Install pressure regulating water circulation pumps for all zones. Install control system for boilers and pumps. Fill system and check for leaks. Add stabilizing chemical to system and check system for proper operation. Also will need to be included in Quote is 4 Air to Air exchangers in Attic and a Heater in the boiler room. The existing piping in the court house will need to be cleaned and flushed minimum of 3 times.**